



Republic of the Philippines  
**LEYTE METROPOLITAN WATER DISTRICT**  
 A DOH ACCREDITED WATER TESTING LABORATORY  
 Accreditation No.: 13-001-08-LW-2  
 Rapid Filtration Plant, Brgy. Hibunawon, Jaro, Leyte  
 Telefax No. (053) 332-7465/332-7424

### BACTERIOLOGICAL TEST RESULT FOR WATER

Name of Client: **CATBALOGAN WATER DISTRICT**  
 Address : Brgy. 4, Allen Avenue, Catbalogan, City

Submitted by: ZALDY A. MAHINAY  
 Contact No.:

Lab. No.	Sample Source and Address	Date and Time of:			Result of Analysis			Remarks
		Collection	Receipt	Examination	Total (MPN)	Fecal (MPN)	HPC (CFU/ML)	
		March 20, 2014						
14-220	Faucet, Brgy. 1, Catbalogan, City	6:56 AM	8:00 PM	9:00 PM	<1.1	<1.1	3	PASSED
14-221	Faucet, Brgy. 8, Catbalogan, City	7:07 AM	8:00 PM	9:05 PM	<1.1	<1.1	1	PASSED
14-222	Faucet, Brgy. Buno-Anan, Catbalogan, City	7:18 AM	8:00 PM	9:10 PM	<1.1	<1.1	15	PASSED
14-223	Faucet, Brgy. Guindapunan, Catbalogan, City	7:30 AM	8:00 PM	9:15 PM	<1.1	<1.1	2	PASSED

Remarks: 1. The results given in this report were obtained at the time of the analysis and refer only to the particular sample submitted.  
 2. This result shall not be reproduced unless in full.

Philippine National Standards for Drinking Water (PNSDW)  
 MPN = Most Probable Number  
 CFU = Colony Forming Unit

MPN/100 ml. Total Coliform =	Refilling Station	Public Water Supplies
MPN/100 ml. Fecal Coliform =	Less than 1.1 or 0	Less than 1.1 or 0
Heterotrophic Plate Count =	Less than 1.1 or 0	Less than 1.1 or 0
	Less than 500 CFU/mL	Less than 500 CFU/mL

Analyst: *Katherine S. Zabala*  
**KATHERINE S. ZABALA, RMT**  
 Medical Technologist

Certified Correct:  
*Rosalinda A. Dumagsa*  
**ROSALINDA A. DUMAGSA**  
 Quality Control/Assurance Officer

Noted: *Cynthia L. Terrado*  
**CYNTHIA L. TERRADO**  
 OIC, Div. Mgr., Quality Control