

Republic of the Philippines
LEYTE METROPOLITAN WATER DISTRICT

A DOH ACCREDITED WATER TESTING LABORATORY

Accreditation No.: 13-001-08-LW-2

Rapid Filtration Plant, Brgy. Hibunawon, Jaro, Leyte

Telefax No. (053) 332-7465/332-7424

BACTERIOLOGICAL TEST RESULT FOR WATER

Name of Client: **Catbalogan Water District**
Address: **Pier 2, Allen Ave., Catbalogan Samar**

Submitted by: **Zaldy Mahinay**
Contact No.:

Lab. No.	Sample Source and Address	Date and Time of:			Result of Analysis			Remarks
		Collection	Receipt	Examination	Total (MPN)	Fecal (MPN)	HPC (CFU/ML)	
		May 23.2014						
14-419	Faucet, CWD , Brgy 3 , Catbalogan City	6:52 AM	1:35 PM	2:45 PM	<1.1	<1.1	34	PASSED
14-420	Faucet, CWD , Brgy 4 , Catbalogan City	7:04 AM	1:35 PM	2:50 PM	<1.1	<1.1	65	PASSED
14-421	Faucet,CWD , Brgy 6 , Catbalogan City	7:15 PM	1:35 PM	2:55 PM	<1.1	<1.1	47	PASSED
14-422	Faucet, CWD, Brgy 8 , Catbalogan City	7:27 AM	1:35 PM	3:00 PM	<1.1	<1.1	51	PASSED
14-423	Faucet, CWD, Brgy 9 , Catbalogan City	7:39 AM	1:35 PM	3:05 PM	<1.1	<1.1	36	PASSED
14-424	Faucet,CWD, Guindapunan , Catbalogan City	7:50 AM	1:35 PM	3:10 PM	<1.1	<1.1	40	PASSED

Remarks: 1. The results given in this report were obtained at the time of the analysis and refer only to the particular sample submitted.
2. This result shall not be reproduced unless in full.

Philippine National Standards for Drinking Water (PNSDW)

MPN = Most Probable Number

CFU = Colony Forming Unit

MPN/100 ml. Total Coliform =
MPN/100 ml. Fecal Coliform =
Heterotrophic Plate Count =

Refilling Station
Less than 1.1 or 0
Less than 1.1 or 0
Less than 500 CFU/mL

Public Water Supplies
Less than 1.1 or 0
Less than 1.1 or 0
Less than 500 CFU/mL

Analyst: *K. Zabala*

Certified Correct:

Noted:

KATHERINE S. ZABALA, RMT
Medical Technologist

Rosalinda A. Dumagsa
ROSALINDA A. DUMAGSA
Quality Control/Assurance Officer

Cynthia L. Terrado
CYNTHIA L. TERRADO
OIC, Div. Mgr., Quality Control



Republic of the Philippines
LEYTE METROPOLITAN WATER DISTRICT

A DOH ACCREDITED WATER TESTING LABORATORY

Accreditation No.: 13-001-08-LW-2

Rapid Filtration Plant, Brgy. Hibunawon, Jaro, Leyte

Telefax No. (053) 332-7465/332-7424

BACTERIOLOGICAL TEST RESULT FOR WATER

Name of Client: **Catbalogan Water District**
 Address: **Pier 2, Allen Ave., Catbalogan Samar**

Submitted by: **Zaldy Mahinay**
 Contact No.:

Lab. No.	Sample Source and Address	Date and Time of:			Result of Analysis			Remarks
		Collection	Receipt	Examination	Total (MPN)	Fecal (MPN)	HPC (CFU/ML)	
		May 23.2014						
14-413	Faucet, CWD , San Andres, Catbalogan City	5:37 AM	1:35 PM	2:15 PM	<1.1	<1.1	41	PASSED
14-414	Faucet, CWD , Canlapwas, Catbalogan City	5:49 AM	1:35 PM	2:20 PM	<1.1	<1.1	89	PASSED
14-415	Faucet, CWD , Muñoz, Catbalogan City	6:03 AM	1:35 PM	2:25 PM	<1.1	<1.1	41	PASSED
14-416	Faucet, CWD , San Pablo, Catbalogan City	6:15 AM	1:35 PM	2:30 PM	<1.1	<1.1	45	PASSED
14-417	Faucet, CWD , Mercedes , Catbalogan City	6:27 AM	1:35 PM	2:35 PM	<1.1	<1.1	36	PASSED
14-418	Faucet, CWD , Brgy 1 , Catbalogan City	6:39 AM	1:35 PM	2:40 PM	<1.1	<1.1	43	PASSED

Remarks: 1. The results given in this report were obtained at the time of the analysis and refer only to the particular sample submitted.
 2. This result shall not be reproduced unless in full.

Philippine National Standards for Drinking Water (PNSDW)

MPN = Most Probable Number

CFU = Colony Forming Unit

MPN/100 ml. Total Coliform =
 MPN/100 ml. Fecal Coliform =
 Heterotrophic Plate Count =

Refilling Station
 Less than 1.1 or 0
 Less than 1.1 or 0
 Less than 500 CFU/ml

Public Water Supplies
 Less than 1.1 or 0
 Less than 1.1 or 0
 Less than 500 CFU/ml

Analyst: *Katherine S. Zabala*

KATHERINE S. ZABALA, RMT
 Medical Technologist

Certified Correct:

Rosalinda A. Dumagsa
ROSALINDA A. DUMAGSA
 Quality Control/Assurance Officer

Noted:

Cynthia L. Terrado
CYNTHIA L. TERRADO
 OIC, Div. Mgr., Quality Control